

HVAC Load Analysis

for

Rock Creek Winery
6025 Rockhill Rd
Aubrey, TX



CHVAC COMMERCIAL
HVAC LOADS

Prepared By:

M. Dunne
DDR Engineering

Saturday, June 1, 2024



Building Summary Loads

Building peaks in August at 10am.

Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	6,192	10,830	5.03	0	3,229	3,229	0.93
Wall	4,642	18,944	8.80	0	8,173	8,173	2.35
Glass	1,148	41,496	19.27	0	98,562	98,562	28.36
Floor Slab	0	0	0.00	0	0	0	0.00
Skin Loads		71,269	33.10	0	109,963	109,963	31.64
Lighting	6,185	0	0.00	0	22,159	22,159	6.38
Equipment	3,025	0	0.00	0	10,835	10,835	3.12
Pool Latent	0	0	0.00	0	0	0	0.00
People	197	0	0.00	39,262	47,527	86,789	24.97
Partition	0	0	0.00	0	0	0	0.00
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	2,371	0	0.00	48,947	38,091	87,038	25.04
Heat. Vent.	2,371	132,680	61.62	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	2,070	2,070	0.60
Blow-Thru Fan	0	0	0.00	0	0	0	0.00
Reserve Cap.	0	0	0.00	0	11,828	11,828	3.40
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	8,544	3.97	0	12,116	12,116	3.49
Return Duct	0	2,829	1.31	0	4,784	4,784	1.38
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
Building Totals		215,321	100.00	88,208	259,373	347,581	100.00

Building Summary	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Ventilation	132,680	61.62	48,947	38,091	87,038	25.04
Infiltration	0	0.00	0	0	0	0.00
Pretreated Air	0	0.00	0	0	0	0.00
Room Loads	71,269	33.10	39,262	202,313	241,574	69.50
Plenum Loads	0	0.00	0	0	0	0.00
Fan/Duct/Misc Loads	11,372	5.28	0	18,969	18,969	5.46
Building Totals	215,322	100.00	88,208	259,373	347,581	100.00

Check Figures

Total Building Supply Air (based on a 18° TD):	11,270 CFM
Total Building Vent. Air (21.04% of Supply):	2,371 CFM
Total Conditioned Air Space:	8,884 Sq.ft
Supply Air Per Unit Area:	1.2685 CFM/Sq.ft
Area Per Cooling Capacity:	306.7 Sq.ft/Ton
Cooling Capacity Per Area:	0.0033 Tons/Sq.ft
Heating Capacity Per Area:	24.24 Btuh/Sq.ft
Total Heating Required With Outside Air:	215,322 Btuh
Total Cooling Required With Outside Air:	28.97 Tons



Air Handler #1 - Main Entry - Summary Loads

Rm No	Description Room Peak Time Zn No., Flr No.	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
1	Main Entry 10am August Zn 1, Flr 1	1,200 12 12,000	10,237 539 0.45	26,111 1,443 1.20	2,394 0 0	5/P, 0.06/ft ² 132 132	5/P, 0.06/ft ² 132 132
	Room Peak Totals:	1,200	10,237	26,111	2,394		
	Total Rooms: 1	12	539	1,443	0	132	132
	Unique Rooms: 1	12,000	0.45	1.20	0	132	132



Air Handler #1 - Main Entry - Total Load Summary

Air Handler Description: Main Entry Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.11 HP
 Fan Input: 85% motor and fan efficiency with 0.4 in. water across the fan
 Sensible Heat Ratio: 0.94 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 10am in August. Method for finding peak time: Adjusted (based on percent sensible capacity)
 Outdoor Conditions: Clg: 87° DB, 71° WB, 92.22 grains, Htg: 22° DB
 Indoor Conditions: Clg: 72° DB, 50% RH, Htg: 75° DB

Summer: Ventilation controls outside air, ----- Winter: Ventilation controls outside air.

Room Space sensible loss:	10,237 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	7,385 Btuh	132 CFM
Supply Duct sensible loss:	1,137 Btuh	
Return Duct sensible loss:	569 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		19,329 Btuh

Heating Supply Air: $11,375 / (.977 \times 1.08 \times 20) =$	539 CFM
Winter Vent Outside Air (24.5% of supply) =	132 CFM

Room space sensible gain:	25,532 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	265 Btuh	
Supply duct sensible gain:	1,551 Btuh	
Reserve sensible gain:	570 Btuh	
Total sensible gain on supply side of coil:		27,917 Btuh

Cooling Supply Air: $27,917 / (.977 \times 1.1 \times 18) =$	1,442 CFM
Summer Vent Outside Air (9.2% of supply) =	132 CFM

Return duct sensible gain:	704 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	2,129 Btuh	132 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		2,833 Btuh
Total sensible gain on air handling system:		30,751 Btuh

Room space latent gain:	1,915 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	2,736 Btuh	
Total latent gain on air handling system:		4,651 Btuh
Total system sensible and latent gain:		35,402 Btuh

Check Figures

Total Air Handler Supply Air (based on a 18° TD):	1,442 CFM
Total Air Handler Vent. Air (9.15% of Supply):	132 CFM
Total Conditioned Air Space:	1,200 Sq.ft
Supply Air Per Unit Area:	1.2020 CFM/Sq.ft
Area Per Cooling Capacity:	351.2 Sq.ft/Ton
Cooling Capacity Per Area:	0.0028 Tons/Sq.ft
Heating Capacity Per Area:	16.11 Btuh/Sq.ft
Total Heating Required With Outside Air:	19,329 Btuh
Total Cooling Required With Outside Air:	3.42 Tons

Note: Tonnages are 'adjusted' tons, based on percent sensible capacity of the air handler.



Air Handler #2 - Hall__Low Roof Section - Summary Loads

Rm No	Description Room Peak Time Zn No., Flr No.	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
2	Hall-Low Roof Section 9am August Zn 2, Flr 1	1,080 48 10,800	12,765 672 0.62	52,930 2,925 2.71	9,576 0 0	7.5/P, 0.06/ft ² 425 425	7.5/P, 0.06/ft ² 425 425
	Room Peak Totals:	1,080	12,765	52,930	9,576		
	Total Rooms: 1	48	672	2,925	0	425	425
	Unique Rooms: 1	10,800	0.62	2.71	0	425	425



Air Handler #2 - Hall__Low Roof Section - Total Load Summary

Air Handler Description: Hall__Low Roof Section Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.22 HP
 Fan Input: 85% motor and fan efficiency with 0.4 in. water across the fan
 Sensible Heat Ratio: 0.88 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 9am in August. Method for finding peak time: Adjusted (based on percent sensible capacity)
 Outdoor Conditions: Clg: 83° DB, 70° WB, 93.84 grains, Htg: 22° DB
 Indoor Conditions: Clg: 72° DB, 50% RH, Htg: 75° DB

Summer: Ventilation controls outside air, ----- Winter: Ventilation controls outside air.

Room Space sensible loss:	12,765 Btuh		
Infiltration sensible loss:	0 Btuh	0 CFM	
Outside Air sensible loss:	23,767 Btuh	425 CFM	
Supply Duct sensible loss:	1,418 Btuh		
Return Duct sensible loss:	709 Btuh		
Return Plenum sensible loss:	0 Btuh		
Total System sensible loss:			38,659 Btuh

Heating Supply Air: 14,183 / (.977 X 1.08 X 20) =			672 CFM
Winter Vent Outside Air (63.2% of supply) =			425 CFM

Room space sensible gain:	50,612 Btuh		
Infiltration sensible gain:	0 Btuh		
Draw-thru fan sensible gain:	537 Btuh		
Supply duct sensible gain:	3,144 Btuh		
Reserve sensible gain:	2,306 Btuh		
Total sensible gain on supply side of coil:			56,599 Btuh

Cooling Supply Air: 56,599 / (.977 X 1.1 X 18) =			2,924 CFM
Summer Vent Outside Air (14.5% of supply) =			425 CFM

Return duct sensible gain:	1,344 Btuh		
Return plenum sensible gain:	0 Btuh		
Outside air sensible gain:	5,024 Btuh	425 CFM	
Blow-thru fan sensible gain:	0 Btuh		
Total sensible gain on return side of coil:			6,368 Btuh
Total sensible gain on air handling system:			62,967 Btuh

Room space latent gain:	7,661 Btuh		
Infiltration latent gain:	0 Btuh		
Outside air latent gain:	9,053 Btuh		
Total latent gain on air handling system:			16,713 Btuh
Total system sensible and latent gain:			79,681 Btuh

Check Figures

Total Air Handler Supply Air (based on a 18° TD):			2,924 CFM
Total Air Handler Vent. Air (14.53% of Supply):			425 CFM
Total Conditioned Air Space:	1,080 Sq.ft		
Supply Air Per Unit Area:	2.7079 CFM/Sq.ft		
Area Per Cooling Capacity:	154.4 Sq.ft/Ton		
Cooling Capacity Per Area:	0.0065 Tons/Sq.ft		
Heating Capacity Per Area:	35.80 Btuh/Sq.ft		
Total Heating Required With Outside Air:	38,659 Btuh		
Total Cooling Required With Outside Air:	7.00 Tons		

Note: Tonnages are 'adjusted' tons, based on percent sensible capacity of the air handler.



Air Handler #3 - Hall-High Roof Section - Summary Loads

Rm No	Description Room Peak Time Zn No., Flr No.	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
3	Hall- 20 Ft High Section 10am August Zn 3, Flr 1	3,280 156 65,600	20,349 1,367 0.42	60,717 3,356 1.02	31,122 0 0	7.5/P, 0.06/ft ² 1,367 1,367	7.5/P, 0.06/ft ² 1,367 1,367
	Room Peak Totals:	3,280	20,349	60,717	31,122		
	Total Rooms: 1	156	1,367	3,356	0	1,367	1,367
	Unique Rooms: 1	65,600	0.42	1.02	0	1,367	1,367



Air Handler #3 - Hall-High Roof Section - Total Load Summary

Air Handler Description: Hall-High Roof Section Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.25 HP
 Fan Input: 85% motor and fan efficiency with 0.4 in. water across the fan
 Sensible Heat Ratio: 0.72 --- This system occurs 1 time(s) in the building. ---
 Air System Peak Time: 8am in August. Method for finding peak time: Adjusted (based on percent sensible capacity)
 Outdoor Conditions: Clg: 81° DB, 70° WB, 96.03 grains, Htg: 22° DB
 Indoor Conditions: Clg: 72° DB, 50% RH, Htg: 75° DB

Summer: Ventilation controls outside air, ----- Winter: Ventilation controls outside air.

Room Space sensible loss:	20,349 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	76,471 Btuh	1,367 CFM
Supply Duct sensible loss:	2,886 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		99,706 Btuh

Heating Supply Air: $23,235 / (.977 \times 1.08 \times 16) =$	1,367 CFM
Winter Vent Outside Air (100.0% of supply) =	1,367 CFM

Room space sensible gain:	51,972 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	616 Btuh	
Supply duct sensible gain:	3,607 Btuh	
Reserve sensible gain:	7,523 Btuh	
Total sensible gain on supply side of coil:		63,718 Btuh

Cooling Supply Air: $64,928 / (.977 \times 1.1 \times 18) =$	3,355 CFM
Summer Vent Outside Air (40.7% of supply) =	1,367 CFM

Return duct sensible gain:	1,069 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	13,226 Btuh	1,367 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		14,295 Btuh
Total sensible gain on air handling system:		78,013 Btuh

Room space latent gain:	24,898 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	32,075 Btuh	
Total latent gain on air handling system:		56,972 Btuh
Total system sensible and latent gain:		134,985 Btuh

Check Figures

Total Air Handler Supply Air (based on a 18° TD):	3,355 CFM
Total Air Handler Vent. Air (40.74% of Supply):	1,367 CFM
Total Conditioned Air Space:	3,280 Sq.ft
Supply Air Per Unit Area:	1.0228 CFM/Sq.ft
Area Per Cooling Capacity:	172.7 Sq.ft/Ton
Cooling Capacity Per Area:	0.0058 Tons/Sq.ft
Heating Capacity Per Area:	30.40 Btuh/Sq.ft
Total Heating Required With Outside Air:	99,706 Btuh
Total Cooling Required With Outside Air:	18.99 Tons

Note: Tonnages are 'adjusted' tons, based on percent sensible capacity of the air handler.



Air Handler #4 - Storage _104 - Summary Loads

Rm No	Description Room Peak Time Zn No., Flr No.	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
4	Storage _104 9am August Zn 4, Flr 1	400 0 4,000	5,923 312 0.78	15,550 811 2.03	0 0 0	None 48 48	None 48 48
	Room Peak Totals:	400	5,923	15,550	0		
	Total Rooms: 1	0	312	811	0	48	48
	Unique Rooms: 1	4,000	0.78	2.03	0	48	48



Air Handler #4 - Storage _104 - Total Load Summary

Air Handler Description: Storage _104 Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.06 HP
 Fan Input: 85% motor and fan efficiency with 0.4 in. water across the fan
 Sensible Heat Ratio: 1.00 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 9am in August. Method for finding peak time: Adjusted (based on percent sensible capacity)
 Outdoor Conditions: Clg: 83° DB, 70° WB, 93.84 grains, Htg: 22° DB
 Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 75° DB

Summer: Ventilation controls outside air, ----- Winter: Ventilation controls outside air.

Room Space sensible loss:	5,923 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	2,686 Btuh	48 CFM
Supply Duct sensible loss:	658 Btuh	
Return Duct sensible loss:	329 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		9,596 Btuh

Heating Supply Air: $6,581 / (.977 \times 1.08 \times 20) =$	312 CFM
Winter Vent Outside Air (15.4% of supply) =	48 CFM

Room space sensible gain:	15,550 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	149 Btuh	
Supply duct sensible gain:	872 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		16,571 Btuh

Cooling Supply Air: $16,571 / (.977 \times 1.1 \times 19) =$	811 CFM
Summer Vent Outside Air (5.9% of supply) =	48 CFM

Return duct sensible gain:	410 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	413 Btuh	48 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		823 Btuh
Total sensible gain on air handling system:		17,394 Btuh

Room space latent gain:	0 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	818 Btuh	
Total latent gain on air handling system:		818 Btuh
Total system sensible and latent gain:		18,212 Btuh

Check Figures

Total Air Handler Supply Air (based on a 19° TD):	811 CFM
Total Air Handler Vent. Air (5.92% of Supply):	48 CFM
Total Conditioned Air Space:	400 Sq.ft
Supply Air Per Unit Area:	2.0279 CFM/Sq.ft
Area Per Cooling Capacity:	207.0 Sq.ft/Ton
Cooling Capacity Per Area:	0.0048 Tons/Sq.ft
Heating Capacity Per Area:	23.99 Btuh/Sq.ft
Total Heating Required With Outside Air:	9,596 Btuh
Total Cooling Required With Outside Air:	1.93 Tons

Note: Tonnages are 'adjusted' tons, based on percent sensible capacity of the air handler.



Air Handler #5 - Kitchen - Summary Loads

Rm No	Description Room Peak Time Zn No., Flr No.	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
5	Kitchen_106 10am August Zn 5, Flr 1	1,008 6 10,080	2,877 151 0.15	17,054 842 0.84	1,197 0 0	None 0 0	None 0 0
	Room Peak Totals:	1,008	2,877	17,054	1,197		
	Total Rooms: 1	6	151	842	0	0	0
	Unique Rooms: 1	10,080	0.15	0.84	0	0	0

**Air Handler #5 - Kitchen - Total Load Summary**

Air Handler Description: Kitchen Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.06 HP
 Fan Input: 85% motor and fan efficiency with 0.4 in. water across the fan
 Sensible Heat Ratio: 0.95 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 10am in August. Method for finding peak time: Adjusted (based on percent sensible capacity)
 Outdoor Conditions: Clg: 87° DB, 71° WB, 92.22 grains, Htg: 22° DB
 Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 75° DB

Summer: Exhaust controls outside air, ---- Winter: Exhaust controls outside air.

Room Space sensible loss:	2,877 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	320 Btuh	
Return Duct sensible loss:	160 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		3,357 Btuh

Heating Supply Air: $3,197 / (.977 \times 1.08 \times 20) =$	151 CFM
Winter Vent Outside Air (0.0% of supply) =	0 CFM

Room space sensible gain:	16,764 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	155 Btuh	
Supply duct sensible gain:	905 Btuh	
Reserve sensible gain:	283 Btuh	
Total sensible gain on supply side of coil:		18,107 Btuh

Cooling Supply Air: $18,107 / (.977 \times 1.1 \times 20) =$	842 CFM
Summer Vent Outside Air (0.0% of supply) =	0 CFM

Return duct sensible gain:	453 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	0 Btuh	0 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		453 Btuh
Total sensible gain on air handling system:		18,560 Btuh

Room space latent gain:	958 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	0 Btuh	
Total latent gain on air handling system:		958 Btuh
Total system sensible and latent gain:		19,517 Btuh

Check Figures

Total Air Handler Supply Air (based on a 20° TD):	842 CFM
Total Air Handler Vent. Air (0.00% of Supply):	0 CFM
Total Conditioned Air Space:	1,008 Sq.ft
Supply Air Per Unit Area:	0.8353 CFM/Sq.ft
Area Per Cooling Capacity:	488.8 Sq.ft/Ton
Cooling Capacity Per Area:	0.0020 Tons/Sq.ft
Heating Capacity Per Area:	3.33 Btuh/Sq.ft
Total Heating Required With Outside Air:	3,357 Btuh
Total Cooling Required With Outside Air:	2.06 Tons

Note: Tonnages are 'adjusted' tons, based on percent sensible capacity of the air handler.



Air Handler #6 - Hallway_106 - Summary Loads

Rm No	Description Room Peak Time Zn No., Flr No.	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
6	Hallway_106 10am August Zn 6, Flr 1	168 0 1,680	3,395 179 1.06	3,995 221 1.31	0 0 0	None 10 10	None 10 10
	Room Peak Totals:	168	3,395	3,995	0		
	Total Rooms: 1	0	179	221	0	10	10
	Unique Rooms: 1	1,680	1.06	1.31	0	10	10



Air Handler #6 - Hallway_106 - Total Load Summary

Air Handler Description: Hallway_106 Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.02 HP
 Fan Input: 85% motor and fan efficiency with 0.4 in. water across the fan
 Sensible Heat Ratio: 1.00 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 10am in August. Method for finding peak time: Adjusted (based on percent sensible capacity)
 Outdoor Conditions: Clg: 87° DB, 71° WB, 92.22 grains, Htg: 22° DB
 Indoor Conditions: Clg: 72° DB, 50% RH, Htg: 75° DB

Summer: Ventilation controls outside air, ----- Winter: Ventilation controls outside air.

Room Space sensible loss:	3,395 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	564 Btuh	10 CFM
Supply Duct sensible loss:	377 Btuh	
Return Duct sensible loss:	189 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		4,525 Btuh

Heating Supply Air: $3,773 / (.977 \times 1.08 \times 20) =$	179 CFM
Winter Vent Outside Air (5.6% of supply) =	10 CFM

Room space sensible gain:	3,995 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	41 Btuh	
Supply duct sensible gain:	237 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		4,273 Btuh

Cooling Supply Air: $4,273 / (.977 \times 1.1 \times 18) =$	221 CFM
Summer Vent Outside Air (4.6% of supply) =	10 CFM

Return duct sensible gain:	113 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	163 Btuh	10 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		276 Btuh
Total sensible gain on air handling system:		4,548 Btuh

Room space latent gain:	0 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	209 Btuh	
Total latent gain on air handling system:		209 Btuh
Total system sensible and latent gain:		4,757 Btuh

Check Figures

Total Air Handler Supply Air (based on a 18° TD):	221 CFM
Total Air Handler Vent. Air (4.57% of Supply):	10 CFM
Total Conditioned Air Space:	168 Sq.ft
Supply Air Per Unit Area:	1.3139 CFM/Sq.ft
Area Per Cooling Capacity:	332.4 Sq.ft/Ton
Cooling Capacity Per Area:	0.0030 Tons/Sq.ft
Heating Capacity Per Area:	26.94 Btuh/Sq.ft
Total Heating Required With Outside Air:	4,525 Btuh
Total Cooling Required With Outside Air:	0.51 Tons

Note: Tonnages are 'adjusted' tons, based on percent sensible capacity of the air handler.



Air Handler #7 - Tasting Room - Summary Loads

Rm No	Description Room Peak Time Zn No., Flr No.	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
7	Tasting Room_107 10am August Zn 7, Flr 1	1,748 24 17,480	15,722 827 0.47	30,301 1,675 0.96	4,788 0 0	7.5/P, 0.12/ft ² 390 390	7.5/P, 0.12/ft ² 390 390
	Room Peak Totals:	1,748	15,722	30,301	4,788		
	Total Rooms: 1	24	827	1,675	0	390	390
	Unique Rooms: 1	17,480	0.47	0.96	0	390	390



Air Handler #7 - Tasting Room - Total Load Summary

Air Handler Description: Tasting Room Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.12 HP
 Fan Input: 85% motor and fan efficiency with 0.4 in. water across the fan
 Sensible Heat Ratio: 0.89 --- This system occurs 1 time(s) in the building. ---
 Air System Peak Time: 10am in August. Method for finding peak time: Adjusted (based on percent sensible capacity)
 Outdoor Conditions: Clg: 87° DB, 71° WB, 92.22 grains, Htg: 22° DB
 Indoor Conditions: Clg: 72° DB, 50% RH, Htg: 75° DB

Summer: Ventilation controls outside air, ----- Winter: Ventilation controls outside air.

Room Space sensible loss:	15,722 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	21,807 Btuh	390 CFM
Supply Duct sensible loss:	1,747 Btuh	
Return Duct sensible loss:	873 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		40,149 Btuh

Heating Supply Air: $17,469 / (.977 \times 1.08 \times 20) =$	827 CFM
Winter Vent Outside Air (47.1% of supply) =	390 CFM

Room space sensible gain:	29,141 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	307 Btuh	
Supply duct sensible gain:	1,800 Btuh	
Reserve sensible gain:	1,146 Btuh	
Total sensible gain on supply side of coil:		32,395 Btuh

Cooling Supply Air: $32,395 / (.977 \times 1.1 \times 18) =$	1,674 CFM
Summer Vent Outside Air (23.3% of supply) =	390 CFM

Return duct sensible gain:	690 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	6,286 Btuh	390 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		6,976 Btuh
Total sensible gain on air handling system:		39,371 Btuh

Room space latent gain:	3,830 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	8,078 Btuh	
Total latent gain on air handling system:		11,909 Btuh
Total system sensible and latent gain:		51,280 Btuh

Check Figures

Total Air Handler Supply Air (based on a 18° TD):	1,674 CFM
Total Air Handler Vent. Air (23.29% of Supply):	390 CFM
Total Conditioned Air Space:	1,748 Sq.ft
Supply Air Per Unit Area:	0.9576 CFM/Sq.ft
Area Per Cooling Capacity:	399.6 Sq.ft/Ton
Cooling Capacity Per Area:	0.0025 Tons/Sq.ft
Heating Capacity Per Area:	22.97 Btuh/Sq.ft
Total Heating Required With Outside Air:	40,149 Btuh
Total Cooling Required With Outside Air:	4.37 Tons

Note: Tonnages are 'adjusted' tons, based on percent sensible capacity of the air handler.